

Type Approval Certificate



This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No.	12 258 - 98 HH
Company	Camille Bauer AG Aargauerstrasse 7 5610 Wohlen, SWITZERLAND
Product Description	Transducer for Current
Type	SINEAX I 538, SINEAX I 542, SINEAX I 552
Environmental Category	C
Technical Data / Range of Application	SINEAX I 538: power supply 24 V DC or 230 V AC Input: 0 - 0.8 A up to 0 - 6 A AC Output: 0 - 20 mA or 4 - 20 mA or 0 - 5 V, 1 - 5 V, 0 - 10 V or 2 - 10 V SINEAX I 542: without power supply Input: 0 - 1 A / 5 A or 0 - 1.2 A / 6 A Output: 0 - 5 mA, 0 - 10 mA or 0 - 20 mA SINEAX I 552: power supply 24 - 60 V or 85 - 230 V AC / DC Input: 0 - 0.1 A / 0.5 A to 0 - 1.2 A / 6 A Output: 0 - 20 mA or 4 - 20 mA or 0 - 5 V, 1 - 5 V, 0 - 10 V or 2 - 10 V Degree of protection: IP 20 DIN - rail snap on connection
Test Standard	Regulations for the Performance of Type Tests Part 2, Edition 2012, EMC2
Documents	Test report : I 538, I 542, I 552 Circuit diagram: Dossiers E250, E251, E247 Data sheet: I538 Lx, I 542 Lx, I 552 Lx
Remarks	None

Valid until 2018-09-19

Page 1 of 1

File No. I.D.15

Hamburg, 2013-09-20

Type Approval Symbol



Germanischer Lloyd

Arne Schaarmann
Arne Schaarmann

Harald Amberger
Harald Amberger

This certificate is issued on the basis of "Guidelines for the Performance of Type Approvals Part 1, Procedure".